



NATIONAL ENVIRONMENT & PLANNING AGENCY

10 & 11 Caledonia Avenue, Kingston 5, Jamaica W.I. Tel: (876) 754-7540/3 Fax: (876) 754-7595-6 Tollfree: 1-888-991-5005
E-mail: ceo@nepa.gov.jm, Website: <http://www.nepa.gov.jm>

AMENDMENT TO

ENVIRONMENTAL PERMIT # 2016-14017-EP00296

Application Date: 8 July 2016

Issue Date of Original Permit: 3 November 2016

Date of Issue of Amendment:

Pursuant to **General Condition 4** of the Environmental Permit # 2016-14017-EP00296 and upon the request of the Permittee **South Jamaica Power Company Limited** of **6 Knutsford Boulevard, Kingston 5** the Natural Resources Conservation Authority (hereinafter referred to as the "Authority") hereby amends the abovementioned Permit in the following manner:-

Specific Condition #5 which reads:

In the event that LNG is not available at the time of start-up, the Permittee shall hereby be permitted to use ADO with a Sulphur content of 0.25% for a period not exceeding one (1) year.

Shall be amended to read:

In the event that Natural Gas is not available to the Permittee at the time of start-up, the Permittee may use ADO with a Sulphur content of 0.25% for a period not exceeding one (1) year from the date on which the power plant is required by South Jamaica Power Company Limited to have entered into commercial operations. The Permittee may also use ADO with a Sulphur content of 0.25% for the purposes of commissioning the power plant.

After the date on which the power plant enters into commercial operations, ADO may be used provided that the stack emission standards as set out in Schedule 11 of the Natural Resources Conservation Authority (Air Quality) Regulations 2006 are not exceeded. The Permittee shall also ensure that during the use of ADO that there is real time online reporting to the Agency/Authority. This mechanism shall be in place and the Agency/Authority so notified at least 1 month before the plant begins commercial operation as per Specific Condition #60".

The following shall also be included:

Specific Condition # 68:

Pursuant to Specific Condition #5, should the testing period extend beyond one (1) year, the Permittee shall ensure that the stack emission standards as set out in Schedule 11 of the Natural Resources Conservation Authority (Air Quality) Regulations 2006 are not exceeded. The Permittee shall also ensure that during this extended period of ADO use that there is real time online reporting to the Agency/Authority. This mechanism shall be in place and the Agency/Authority so notified at least 1 month before the extended period of ADO use during the testing period.

Definitions

"Commercial Operations" means the commencement of operations after the required testing has been conducted.

Any reply or subsequent reference to this communication should be addressed to the Chief Executive Officer, to the attention of the officer dealing with the matter, and the reference quoted where applicable.

These changes shall be read as one with Environmental Permit No. 2016-14017-EP00296 and shall now apply in every particular to **South Jamaica Power Company Limited**.

Dated this *21st* day of *December*, 2016



PETER KNIGHT, J.P.
for Natural Resources Conservation Authority



MORJORN WALLOCK
Secretary
Natural Resources Conservation Authority